

# Certificate of Analysis



Report Number: **WAK/2868012/2025**  
 Laboratory Number **25503140**

Issue **1**  
 Sample **1** of **8**

Sample Source: **North Yorkshire Council**  
 Sample Point Description: **Private Water Limits**  
 Sample Description: **2025/95 CARLTON PARK VIEW**  
 Sample Matrix: **Drinking Water**

Sample Date: **31 July 2025**      Sample Received: **31 July 2025**      Analysis Complete: **13 August 2025**

Test Description	Result	Units	Limit	Accreditation	Method
Aluminium, Total as Al	9.42	ug/l	200	Y Wak	WPC12/49
Iron, Total as Fe	91.4	ug/l	200	Y Wak	WPC12/49
Manganese, Total as Mn	<1.54	ug/l	50	Y Wak	WPC12/49
Hydrogen ion (pH)	7.67	pH units	6.5 to 9.5	Y Wak	WPC8
Conductivity	297	uS/cm	2500	Y Wak	WPC7
Turbidity	0.24	NTU	4	Y Wak	WPC6
Colour	5.4	mg/l Pt/Co	20	Y Wak	WPC13
Ammonium ammonia+ammonium ion	<0.010	mg/l	0.5	Y Wak	WPC64
Nitrite as NO2	<0.003	mg/l	0.5	Y Wak	WPC64
Nitrate as NO3 (Calculated)	<2.13	mg/l	50	Y Wak	WPC64
Total Oxidised Nitrogen as NO3	<2.13	mg/l	50	Y Wak	WPC64
TVC, 3Day 22C	0	cfu/ml		Y Wak	WPM1
TVC, 2Day 37C	0	cfu/ml		Y Wak	WPM1
Escherichia coli, confirmed	0	cfu/100ml	0	Y Wak	WPM4
Clostridium Perfringens	0	cfu/100ml	0	Y Wak	WPM3
Clostridium perfringens presum	0	cfu/100ml	0	Y Wak	WPM3
Total Coliforms, presumptive	0	cfu/100ml	0	Y Wak	WPM4
Escherichia coli, presumptive	0	cfu/100ml	0	Y Wak	WPM4
Faecal Streptococci, presumpti	0	cfu/100ml	0	Y Wak	WPM2
Faecal Streptococci, Confirmed	0	cfu/100ml	0	Y Wak	WPM2
Qualitative Odour	0	Text		N Cov	W56
Qualitative Taste	0	Text		N Cov	W56
Total Coliforms, Conf	0	cfu/100ml		Y Wak	WPM4

**Analyst Comments for 25503140:**      No Analyst Comment

This issue replaces all previous issues  
 Accreditation Codes: Y = UKAS / ISO17025 Accredited, N = Not UKAS / ISO17025 Accredited, M = MCERTS.  
 Analysed at: Che = Chester(CH5 3US), Cov = Coventry(CV4 9GU), S = Subcontracted, Trb = Subcontracted to Trowbridge(BA14 0XD), Wak = Wakefield(WF5 9TG), F = Data supplied by customer.  
 For Microbiological determinands 0 or ND=Not Detected, For Legionella ND=Not Detected in volume of sample filtered.  
 I/S=Insufficient sample For soil/sludge samples: AR=As received, DW=Dry weight.

## ALS Laboratories (UK) Limited

Unit 11, Silkwood Park, Janes Hill, Off Albert Drive, Wakefield, WF5 9TG Tel:+44 (0)1924 818100