



Carlton Village Water Committee  
C/o Mrs Marina Briggs  
Quakers Garth  
Carlton  
Leyburn  
North Yorkshire  
DL8 4BA

My Ref: PWS2  
Dealt with by: Carol Little  
Email: [carol.little@northyorks.gov.uk](mailto:carol.little@northyorks.gov.uk)  
Tel. 0300 131 2 131  
11 July 2024

Dear Madam

**Private Water Supplies (England) Regulations 2016 as amended**

Samples of the Carlton private water supply collected on 12 June 2024 failed to meet the requirements of the above regulations for total Coliforms and E.coli.

Further samples were collected on 20 June 2024 after remedial works and were found to be satisfactory.

Copies of the results are enclosed for your records.

Yours faithfully

Carol Little  
Technical Officer  
01748 901172

# Certificate of Analysis



Report Number: **WAK/2671717/2024**

Issue **2**

Laboratory Number **24126418**

Sample **6** of **11**

Sample Source: **North Yorkshire Council**

Sample Point Description: **Private Water Limits**

Sample Description: **2024/95 CARLTON HOWDEN COTTAGE**

Sample Matrix: **Drinking Water**

Sample Date: **12 June 2024** Sample Received **12 June 2024** Analysis Complete: **28 June 2024**

Test Description	Result	Units	Limit	Accreditation	Method
Escherichia coli, confirmed	3	cfu/100ml	0	Y Wak	WPM4
Total Coliforms, Conf	26	cfu/100ml		Y Wak	WPM4
Total Coliforms, presumptive	26	cfu/100ml	0	Y Wak	WPM4
Escherichia coli, presumptive	3	cfu/100ml	0	Y Wak	WPM4

**Analyst Comments for 24126418:**

This sample has been analysed for Total Coliforms, Conf outside recommended stability times. It is therefore possible that the results provided may be compromised.

This issue replaces all previous issues.

Accreditation Codes: Y = UKAS / ISO17025 Accredited, N = Not-UKAS / ISO17025 Accredited, M = MCERTS.

Analysed at: CHE = Chester(CH5 3US), COV = Coventry(CV4 9GU), S = Subcontracted, TRB = Subcontracted to Trowbridge(BA14 0XD), WAK = Wakefield(WF5 9TG).

For Microbiological determinands 0 or ND=Not Detected, For Legionella ND=Not Detected in volume of sample filtered.

I/S=Insufficient sample For soil/sludge samples: AR=As received, DW=Dry weight.

# Certificate of Analysis



Report Number: **WAK/2671717/2024**

Issue **2**

Laboratory Number **24126419**

Sample **7** of **11**

Sample Source: **North Yorkshire Council**

Sample Point Description: **Private Water Limits**

Sample Description: **2024/96 MOORCOCK HOUSE**

Sample Matrix: **Drinking Water**

Sample Date: **12 June 2024**    Sample Received **12 June 2024**    Analysis Complete: **28 June 2024**

Test Description	Result	Units	Limit	Accreditation	Method
Escherichia coli, confirmed	10	cfu/100ml	0	Y, Wak	WPM4
Total Coliforms, Conf	52	cfu/100ml		Y, Wak	WPM4
Total Coliforms, presumptive	52	cfu/100ml	0	Y, Wak	WPM4
Escherichia coli, presumptive	10	cfu/100ml	0	Y, Wak	WPM4

**Analyst Comments for 24126419:**

This sample has been analysed for Total Coliforms, Conf outside recommended stability times. It is therefore possible that the results provided may be compromised.

This issue replaces all previous issues

Accreditation Codes: Y = UKAS / ISO17025 Accredited, N = Not UKAS / ISO17025 Accredited, M = MCERTS.

Analysed at: CHE = Chester(CH5 3US), COV = Coventry(CV4 9GU), S = Subcontracted, TRB = Subcontracted to Trowbridge(BA14 0XD), WAK = Wakefield(WF5 9TG).

For Microbiological determinands 0 or ND=Not Detected, For Legionella ND=Not Detected in volume of sample filtered.

I/S=Insufficient sample For soil/sludge samples: AR=As received, DW=Dry weight.

# Certificate of Analysis



Report Number: **WAK/2671717/2024**

Issue **2**

Laboratory Number **24126420**

Sample **8** of **11**

Sample Source: **North Yorkshire Council**

Sample Point Description: **Private Water Limits**

Sample Description: **2024/97 CARLTON THE BUNGALOW**

Sample Matrix: **Drinking Water**

Sample Date: **12 June 2024** Sample Received **12 June 2024** Analysis Complete: **28 June 2024**

Test Description	Result	Units	Limit	Accreditation	Method
Escherichia coli, confirmed	10	cfu/100ml	0	Y Wak	WPM4
Total Coliforms, Conf	33	cfu/100ml		Y Wak	WPM4
Total Coliforms, presumptive	33	cfu/100ml	0	Y Wak	WPM4
Escherichia coli, presumptive	10	cfu/100ml	0	Y Wak	WPM4

**Analyst Comments for 24126420:**

This sample has been analysed for Total Coliforms, Conf outside recommended stability times. It is therefore possible that the results provided may be compromised.

This issue replaces all previous issues  
 Accreditation Codes: Y = UKAS / ISO17025 Accredited, N = Not UKAS / ISO17025 Accredited, M = MCERTS.  
 Analysed at: CHE = Chester(CH5 3US), COV = Coventry(CV4 9GU), S = Subcontracted, TRB = Subcontracted to Trowbridge(BA14 0XD), WAK = Wakefield(WF5 9TG).  
 For Microbiological determinands 0 or ND=Not Detected, For Legionella ND=Not Detected in volume of sample filtered.  
 I/S=Insufficient sample For soil/sludge samples: AR=As received, DW=Dry weight.

# Certificate of Analysis



Report Number: **WAK/2676287/2024**

Issue **1**

Laboratory Number **24159378**

Sample **4** of **12**

Sample Source: **North Yorkshire Council**

Sample Point Description: **Private Water Limits**

Sample Description: **2024/104 Carlton Foresters Arms**

Sample Matrix: **Drinking Water**

Sample Date: **20 June 2024**

Sample Received

**21 June 2024**

Analysis Complete:

**08 July 2024**

Test Description	Result	Units	Limit	Accreditation		Method
Total Coliforms confirmed	0	cfu/100ml	0	Y	Cov	W10
Escherichia coli confirmed	0	cfu/100ml	0	Y	Cov	W10
Total Coliform presumpt	0	cfu/100ml	0	Y	Cov	W10
E.coli presumptive	0	cfu/100ml	0	Y	Cov	W10

**Analyst Comments for 24159378:**

This sample has been analysed for Total Coliforms confirmed, Escherichia coli confirmed, Total Coliform presumpt, E.coli presumptive outside recommended stability times. It is therefore possible that the results provided may be compromised.

This issue replaces all previous issues

Accreditation Codes: Y = UKAS / ISO17025 Accredited, N = Not UKAS / ISO17025 Accredited, M = MCERTS.

Analysed at: CHE = Chester(CH5 3US), COV = Coventry(CV4 9GU), S = Subcontracted, TRB = Subcontracted to Trowbridge(BA14 0XD), WAK = Wakefield(WF5 9TG).

For Microbiological determinands 0 or ND=Not Detected, For Legionella ND=Not Detected in volume of sample filtered.

I/S=Insufficient sample For soil/sludge samples: AR=As received, DW=Dry weight.

# Certificate of Analysis



Report Number: **WAK/2676287/2024**

Issue **1**

Laboratory Number **24159379**

Sample **5** of **12**

Sample Source: **North Yorkshire Council**

Sample Point Description: **Private Water Limits**

Sample Description: **2024/105 Carlton Moorcock House**

Sample Matrix: **Drinking Water**

Sample Date: **20 June 2024**

Sample Received

**21 June 2024**

Analysis Complete:

**08 July 2024**

Test Description	Result	Units	Limit	Accreditation		Method
Total Coliforms confirmed	0	cfu/100ml	0	Y	Cov	W10
Escherichia coli confirmed	0	cfu/100ml	0	Y	Cov	W10
Total Coliform presumpt	0	cfu/100ml	0	Y	Cov	W10
E.coli presumptive	0	cfu/100ml	0	Y	Cov	W10

**Analyst Comments for 24159379:**

This sample has been analysed for Total Coliforms confirmed, Escherichia coli confirmed, Total Coliform presumpt, E.coli presumptive outside recommended stability times. It is therefore possible that the results provided may be compromised.

This issue replaces all previous issues

Accreditation Codes: Y = UKAS / ISO17025 Accredited, N = Not UKAS / ISO17025 Accredited, M = MCERTS.

Analysed at: CHE = Chester(CH5 3US), COV = Coventry(CV4 9GU), S = Subcontracted, TRB = Subcontracted to Trowbridge(BA14 0XD), WAK = Wakefield(WF5 9TG).

For Microbiological determinands 0 or ND=Not Detected, For Legionella ND=Not Detected in volume of sample filtered.

I/S=Insufficient sample For soil/sludge samples: AR=As received, DW=Dry weight.